

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0065:153 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Faraday, 805 S.Maumee St., Tecumseh MI 49286  
Contact: Steven A. Blohm (517) 423-2111

**DESIGN:** Models **FireWatch 400** 13400-120 and 13400-240 fire alarm control units. Noncoded, automatic, manual, local, auxiliary, remote station (protected premise), waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

13400-120, 13400-240	FireWatch 400 Mainboard
13402	Alarm Relay Board
13403	City Tie Board
13406	Remote LED Annunciator Driver Board

**RATING:** 13400-120: 120 VAC, 24 VDC  
13400-240: 240 VAC, 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

06-29-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager